

Support

Pipe size

The nominal diameter of the support must be, at least, that of the pipe.

DN Support \geq DN Pipe: 50 ³ 20 mm ✓

Distance between hangers

The maximum distance between hangers shall not exceed that specified in Table 9.2.2.1 (b).

Pipe material	Nominal pipe size	Distance between hangers
Steel	20 mm	Not applicable

Distance between hangers: Not applicable ✓

Hanger rod size

Hanger rod size shall be the same as that approved for use with the hanger assembly, and the size of rods shall not be less than that given in Table 9.1.2.1.

Pipe size	Hanger rod size
50 mm	10 mm

Hanger rod size: 10 ³ 10 mm ✓