

1.- GENERAL DATA..... 2

2.- LOAD CALCULATION SUMMARY..... 3

    2.1.- Cooling..... 3

    2.2.- Heating..... 3

    2.3.- Graphs..... 4

3.- LOAD CALCULATION PER ROOM..... 6

    3.1.- Cooling..... 6

    3.2.- Heating..... 21

    3.3.- Graphs..... 35

# Loads summary

## 1.- GENERAL DATA

### Geographic information

Location	Latitude	Longitude	Elevation	Time zone	Daylight saving time (DST)	
	(°)	(°)	(m)		First month	Last month
LONDON WEATHER CENT	51.52	-0.10	43.00	GMT 0.00	April	October

### Heating design conditions

Dry bulb temperature (°C)	Relative humidity (%)	Ground temperature (°C)
0.40	80.0	7.34

### Cooling design conditions

	January	February	March	April	May	June	July	August	September	October	November	December
Temperatures												
DB (°C)	12.60	13.10	15.60	19.00	23.80	26.60	28.20	28.40	24.10	19.00	15.20	13.50
MDBR (°C)	4.00	4.40	5.50	6.60	7.40	7.50	7.60	7.30	6.40	5.20	4.30	3.80
MCWB (°C)	10.30	10.40	10.20	11.60	15.60	17.50	18.10	18.40	17.00	14.80	12.90	11.40
MCWBR (°C)	4.80	3.90	4.00	4.00	4.90	4.90	3.90	3.70	3.70	3.60	3.70	4.40
Solar radiation												
$\tau_b$	0.333	0.344	0.411	0.408	0.436	0.451	0.470	0.442	0.397	0.372	0.347	0.342
$\tau_d$	2.272	2.240	1.977	2.012	1.955	1.945	1.913	2.003	2.144	2.173	2.226	2.235

### Abbreviations

DST	Daylight Saving Time
DB	Dry-Bulb
MDBR	Mean dry-bulb range
MCWB	Mean coincident wet-bulb
MCWBR	Mean coincident wet-bulb range
$t_b$	Clear sky optical depth for beam irradiance
$t_d$	Clear sky optical depth for diffuse irradiance

## Loads summary

### 2.- LOAD CALCULATION SUMMARY

#### 2.1.- Cooling

##### Zone cooling loads summary:

	External					Internal		Ventilation			Total		Total (W)	
	A (m <sup>2</sup> )	Conduction (W)	Solar (W)	Lat. inf. (W)	Sens. inf. (W)	Lat. (W)	Sens. (W)	Airflow (l/s)	Lat. (W)	Sens. (W)	Lat. (W)	Sens. (W)		Total (W/m <sup>2</sup> )
Peak cooling loads per room														
Lounge	38.0	157.5	923.9	0.0	0.0	26.6	140.5	28.5	-12.0	147.1	14.6	1369.1	36.4	1383.7
Kitchen	11.8	81.7	460.8	0.0	0.0	8.3	42.8	8.9	-3.7	45.7	4.5	631.0	53.9	635.6
Bedroom1	17.0	83.6	49.8	0.0	0.0	11.9	130.8	12.8	-28.3	40.8	-16.4	305.0	17.0	288.7
Bedroom2	14.4	5.7	286.4	0.0	0.0	5.0	51.4	10.8	-56.4	-38.0	-51.4	305.5	17.6	254.1
Bedroom3	22.3	145.7	49.7	0.0	0.0	15.6	171.7	16.7	-37.1	53.6	-21.5	420.6	17.9	399.2
Hall	17.7	28.4	41.1	0.0	0.0	24.8	195.2	13.3	-7.7	64.8	17.1	329.5	19.6	346.6
Bathroom	12.3	30.3	0.0	0.0	0.0	8.6	100.1	9.2	-12.4	31.8	-3.8	162.2	12.9	158.3

Zone simultaneous peak cooling load: 21 of August at 16 (15 apparent solar time)

133.5	100.1	63.8	3325.8	25.4	3389.6
-------	-------	------	--------	------	--------

##### Abbreviations

A	Area
Conduction	Conduction heating load
Solar	Solar heating load
Lat. inf.	Latent infiltration
Sens. inf.	Sensible infiltration
Lat.	Latent
Sens.	Sensible

#### 2.2.- Heating

##### Zone heating loads summary:

	External				Ventilation			Total		Total (W)	
	A (m <sup>2</sup> )	Conduction (W)	Lat. inf. (W)	Sens. inf. (W)	Airflow (l/s)	Lat. (W)	Sens. (W)	Lat. (W)	Sens. (W)		
Peak heating loads per room											
Lounge	38.0	1114.4	0.0	0.0	28.5	138.9	759.7	138.9	1874.1	53.0	2013.0
Kitchen	11.8	420.8	0.0	0.0	8.9	43.1	235.9	43.1	656.7	59.3	699.8
Bedroom1	17.0	488.3	0.0	0.0	12.8	62.1	339.9	62.1	828.2	52.4	890.3
Bedroom2	14.4	365.5	0.0	0.0	10.8	52.6	287.9	52.6	653.4	49.0	706.1
Bedroom3	22.3	674.1	0.0	0.0	16.7	81.5	445.8	81.5	1120.0	53.9	1201.5
Hall	17.7	238.0	0.0	0.0	13.3	64.7	353.9	64.7	591.9	37.1	656.6
Bathroom	12.3	489.6	0.0	0.0	9.2	72.4	280.8	72.4	770.4	68.7	842.8

Zone simultaneous peak heating load

133.5	100.1	515.3	6494.8	52.5	7010.1
-------	-------	-------	--------	------	--------


##### Abbreviations

# Loads summary


A	Area
Conduction	Conduction heating load
Solar	Solar heating load
Lat. inf.	Latent infiltration
Sens. inf.	Sensible infiltration
Lat.	Latent
Sens.	Sensible

## 2.3.- Graphs

Simultaneous peak cooling load (3390 W)  
21 of August at 16h (15 apparent solar time)




Peak heating load (7010 W)



Hourly peak cooling load progression (21 of August)


Produced by a version for internal use of CYPE

# Loads summary



Produced by a version for internal use of CYPE

## Annual peak cooling load progression



## Loads summary

### 3.- LOAD CALCULATION PER ROOM

#### 3.1.- Cooling

Peak cooling load	
Room: Lounge	Zone:
Net floor area: 38.00 m <sup>2</sup> Net volume: 96.83 m <sup>3</sup>	
Design conditions	
Indoor:	Outdoor:
Room air temperature = 24.00 °C	Dry-bulb temperature = 28.4 °C
Relative humidity = 50.00%	Wet-bulb temperature = 18.4 °C
Time of peak cooling load: 21 of August at 16h (15 apparent solar time)	

Produced by a version for internal use of CYPE

Conduction heat gains (opaque surfaces)									
	T <sub>sa</sub>	Ori.	A	U	a	Tilt	Convective component	Radiative component	Sensible cooling load
	(°C)	(°)	(m <sup>2</sup> )	(W/(m <sup>2</sup> K))		(°)	(W)	(W)	(W)
Exterior surface									
Roof	39.17	N(0)	38.00	0.29	0.60	H(0)	17.38	12.66	30.04
NW Façade	37.24	NW(309)	15.70	0.59	0.60	V(90)	6.35	6.49	12.83
SW Façade	47.86	SW(219)	13.80	0.59	0.60	V(90)	15.09	12.18	27.27
SE Façade	31.53	SE(129)	10.80	0.59	0.60	V(90)	25.65	14.28	39.93
								TOTAL:	110.1

#### Abbreviations

T <sub>sa</sub>	Sol-air temperature
Ori.	Orientation
A	Area
U	Heat transmission coefficient
a	Absorptance
Tilt	Tilt angle

#### Conduction heat gains (fenestration)

	Ori.	A	U <sub>global</sub>	Convective component	Radiative component	Sensible cooling load
	(°)	(m <sup>2</sup> )	(W/(m <sup>2</sup> K))	(W)	(W)	(W)
Exterior surface						
Window1	SW(219)	1.80	3.66	19.41	4.33	23.73
Window2	SW(219)	1.80	3.66	19.41	4.33	23.73

## Loads summary

TOTAL: 47.5

### Abbreviations

Ori.	Orientation
A	Area
U <sub>global</sub>	Fenestration global thermic coefficient

### Solar radiation heat gain

	Ori. (°)	A (m <sup>2</sup> )	A <sub>s</sub> (m <sup>2</sup> )	q (°)	SHGC	Beam solar heat gain (W)	Diffuse solar heat gain (W)	Sensible cooling load (W)
Exterior surface								
Window1	SW(219)	1.80	1.80	40.72	0.68	357.40	134.72	461.97
Window2	SW(219)	1.80	1.80	40.72	0.68	357.40	134.72	461.97
TOTAL:								923.9

### Abbreviations

Ori.	Orientation
A	Area
A <sub>s</sub>	Sunlit area
q	Incident angle
SHGC	Center-of-glazing solar heat gain coefficient, SHGC

### Internal heat gains

	Sensible heat gain (W)	Convective component (W)	Radiative component (W)	Latent cooling gain/load (W)	Sensible cooling load (W)
Internal gains					
Occupancy	41.80	16.72	23.47	26.60	40.19
Lighting	50.16	20.06	30.10	-	50.17
Internal equipment	50.16	25.08	25.09	0.00	50.17
TOTAL:				27	141

### Ventilation and infiltration heat gains

	Airflow rate (m <sup>3</sup> /h)	Sensible heat recovery (W)	Latent heat recovery (W)	Latent cooling load (W)	Sensible cooling load (W)
Ventilation					
Ventilation	102.60	-0.00	0.00	-11.96	147.11
TOTAL:				-12	147

# Loads summary

Total cooling load						
Total load per unit area (W/m <sup>2</sup> )	Sensible heat factor	Convective component (W)	Radiative component (W)	Latent cooling load (W)	Sensible cooling load (W)	TOTAL COOLING LOAD (W)
36.4	0.99	165.1	132.9	14.6	1369.1	1383.7 W

Produced by a version for internal use of CYPE



## Loads summary

Peak cooling load	
Room: Kitchen	Zone:
Net floor area: 11.80 m <sup>2</sup> Net volume: 30.66 m <sup>3</sup>	
Design conditions	
Indoor:	Outdoor:
Room air temperature = 24.00 °C	Dry-bulb temperature = 28.4 °C
Relative humidity = 50.00%	Wet-bulb temperature = 18.4 °C
Time of peak cooling load: 21 of August at 16h (15 apparent solar time)	

### Conduction heat gains (opaque surfaces)

	T <sub>sa</sub> (°C)	Ori. (°)	A (m <sup>2</sup> )	U (W/(m <sup>2</sup> K))	a	Tilt (°)	Convective component (W)	Radiative component (W)	Sensible cooling load (W)
Exterior surface									
Azotea	39.17	N(0)	11.80	0.29	0.60	H(0)	5.40	3.99	9.38
Fachada SW	47.86	SW(219)	6.10	0.59	0.60	V(90)	6.44	4.14	10.59
Fachada SE	31.53	SE(129)	11.30	0.59	0.60	V(90)	26.84	12.28	39.12
TOTAL:									59.1

#### Abbreviations

T <sub>sa</sub>	Sol-air temperature
Ori.	Orientation
A	Area
U	Heat transmission coefficient
a	Absorptance
Tilt	Tilt angle

### Conduction heat gains (fenestration)

	Ori. (°)	A (m <sup>2</sup> )	U <sub>global</sub> (W/(m <sup>2</sup> K))	Convective component (W)	Radiative component (W)	Sensible cooling load (W)
Exterior surface						
Ventana1	SW(219)	1.80	3.66	19.41	3.21	22.62
TOTAL:						22.6

#### Abbreviations

Ori.	Orientation
A	Area

## Loads summary

$U_{global}$  Fenestration global thermic coefficient

### Solar radiation heat gain

Ori. (°)	A (m <sup>2</sup> )	A <sub>s</sub> (m <sup>2</sup> )	q (°)	SHGC	Beam solar heat gain (W)	Diffuse solar heat gain (W)	Sensible cooling load (W)	
Exterior surface								
Ventana1	SW(219)	1.80	1.80	40.72	0.68	357.40	134.72	460.80
TOTAL:							460.8	

### Abbreviations

Ori.	Orientation
A	Area
A <sub>s</sub>	Sunlit area
q	Incident angle
SHGC	Center-of-glazing solar heat gain coefficient, SHGC

### Internal heat gains

	Sensible heat gain (W)	Convective component (W)	Radiative component (W)	Latent cooling gain/load (W)	Sensible cooling load (W)
Internal gains					
Occupancy	12.98	5.19	6.77	8.26	11.96
Lighting	15.58	6.23	9.20	-	15.43
Internal equipment	15.58	7.79	7.66	0.00	15.45
TOTAL:				8	43

Produced by a version for internal use of CYPE

### Ventilation and infiltration heat gains

Airflow rate (m <sup>3</sup> /h)	Sensible heat recovery (W)	Latent heat recovery (W)	Latent cooling load (W)	Sensible cooling load (W)	
Ventilation					
Ventilation	31.86	-0.00	0.00	-3.71	45.68
TOTAL:			-4	46	

### Total cooling load

Total load per unit area (W/m <sup>2</sup> )	Sensible heat factor	Convective component (W)	Radiative component (W)	Latent cooling load (W)	Sensible cooling load (W)	TOTAL COOLING LOAD (W)
53.9	0.99	77.3	47.2	4.5	631.0	635.6 W

## Loads summary

Peak cooling load	
Room: Bedroom1	Zone:
Net floor area: 17.00 m <sup>2</sup> Net volume: 44.06 m <sup>3</sup>	
Design conditions	
Indoor:	Outdoor:
Room air temperature = 24.00 °C	Dry-bulb temperature = 26.7 °C
Relative humidity = 50.00%	Wet-bulb temperature = 17.3 °C
Time of peak cooling load: 21 of July at 19h (18 apparent solar time)	

### Conduction heat gains (opaque surfaces)

	T <sub>sa</sub> (°C)	Ori. (°)	A (m <sup>2</sup> )	U (W/(m <sup>2</sup> K))	a	Tilt (°)	Convective component (W)	Radiative component (W)	Sensible cooling load (W)
Exterior surface									
Azotea	28.40	N(0)	17.00	0.29	0.60	H(0)	11.67	7.90	19.57
Fachada NW	39.58	NW(309)	10.60	0.59	0.60	V(90)	14.17	8.12	22.30
Fachada NE	28.39	NE(39)	9.40	0.59	0.60	V(90)	15.60	9.86	25.46
TOTAL:									67.3

#### Abbreviations

T <sub>sa</sub>	Sol-air temperature
Ori.	Orientation
A	Area
U	Heat transmission coefficient
a	Absorptance
Tilt	Tilt angle

### Conduction heat gains (fenestration)

	Ori. (°)	A (m <sup>2</sup> )	U <sub>global</sub> (W/(m <sup>2</sup> K))	Convective component (W)	Radiative component (W)	Sensible cooling load (W)
Exterior surface						
Ventana1	NE(39)	1.80	3.66	11.98	4.32	16.30
TOTAL:						16.3

#### Abbreviations

Ori.	Orientation
A	Area

## Loads summary

$U_{global}$  Fenestration global thermic coefficient

### Solar radiation heat gain

Ori. (°)	A (m <sup>2</sup> )	A <sub>s</sub> (m <sup>2</sup> )	q (°)	SHGC	Beam solar heat gain (W)	Diffuse solar heat gain (W)	Sensible cooling load (W)	
Exterior surface								
Ventana1	NE(39)	1.80	1.80	115.93	0.68	0.00	42.31	49.77
TOTAL:							49.8	

### Abbreviations

Ori.	Orientation
A	Area
A <sub>s</sub>	Sunlit area
q	Incident angle
SHGC	Center-of-glazing solar heat gain coefficient, SHGC

### Internal heat gains

	Sensible heat gain (W)	Convective component (W)	Radiative component (W)	Latent cooling gain/load (W)	Sensible cooling load (W)
Internal gains					
Occupancy	18.70	7.48	10.78	11.90	18.26
Lighting	74.80	29.92	24.67	-	54.59
Internal equipment	74.80	37.40	20.56	0.00	57.96
TOTAL:				12	131

Produced by a version for internal use of CYPE

### Ventilation and infiltration heat gains

Airflow rate (m <sup>3</sup> /h)	Sensible heat recovery (W)	Latent heat recovery (W)	Latent cooling load (W)	Sensible cooling load (W)	
Ventilation					
Ventilation	45.90	-0.00	0.00	-28.28	40.84
TOTAL:			-28	41	

### Total cooling load

Total load per unit area (W/m <sup>2</sup> )	Sensible heat factor	Convective component (W)	Radiative component (W)	Latent cooling load (W)	Sensible cooling load (W)	TOTAL COOLING LOAD (W)
17.0	1.06	128.2	86.2	-16.4	305.0	288.7 W

## Loads summary

Peak cooling load	
Room: Bedroom2	Zone:
Net floor area: 14.40 m <sup>2</sup> Net volume: 37.40 m <sup>3</sup>	
Design conditions	
Indoor:	Outdoor:
Room air temperature = 24.00 °C	Dry-bulb temperature = 21.1 °C
Relative humidity = 50.00%	Wet-bulb temperature = 14.4 °C
Time of peak cooling load: 21 of July at 8h (7 apparent solar time)	

### Conduction heat gains (opaque surfaces)

	T <sub>sa</sub>	Ori.	A	U	a	Tilt	Convective component	Radiative component	Sensible cooling load
	(°C)	(°)	(m <sup>2</sup> )	(W/(m <sup>2</sup> K))		(°)	(W)	(W)	(W)
Exterior surface									
Azotea	25.96	N(0)	14.40	0.29	0.60	H(0)	11.04	7.55	18.59
Fachada NE	33.55	NE(39)	6.30	0.59	0.60	V(90)	1.02	3.82	4.84
TOTAL:									23.4

Produced by a version for internal use of CYPE

#### Abbreviations

T <sub>sa</sub>	Sol-air temperature
Ori.	Orientation
A	Area
U	Heat transmission coefficient
a	Absorptance
Tilt	Tilt angle

### Conduction heat gains (fenestration)

	Ori.	A	U <sub>global</sub>	Convective component	Radiative component	Sensible cooling load
	(°)	(m <sup>2</sup> )	(W/(m <sup>2</sup> K))	(W)	(W)	(W)
Exterior surface						
Ventana1	NE(39)	1.80	3.66	-12.91	-4.77	-17.68
TOTAL:						-17.7

#### Abbreviations

Ori.	Orientation
A	Area
U <sub>global</sub>	Fenestration global thermic coefficient

## Loads summary

### Solar radiation heat gain

	Ori. (°)	A (m <sup>2</sup> )	A <sub>s</sub> (m <sup>2</sup> )	q (°)	SHGC	Beam solar heat gain (W)	Diffuse solar heat gain (W)	Sensible cooling load (W)
Exterior surface								
Ventana1	NE(39)	1.80	1.80	52.30	0.68	220.14	95.21	286.37
TOTAL:								286.4

### Abbreviations

Ori.	Orientation
A	Area
A <sub>s</sub>	Sunlit area
q	Incident angle
SHGC	Center-of-glazing solar heat gain coefficient, SHGC

### Internal heat gains

	Sensible heat gain (W)	Convective component (W)	Radiative component (W)	Latent cooling gain/load (W)	Sensible cooling load (W)
Internal gains					
Occupancy	7.92	3.17	11.22	5.04	14.39
Lighting	19.01	7.60	10.84	-	18.44
Internal equipment	19.01	9.50	9.03	0.00	18.54
TOTAL:				5	51

### Ventilation and infiltration heat gains

	Airflow rate (m <sup>3</sup> /h)	Sensible heat recovery (W)	Latent heat recovery (W)	Latent cooling load (W)	Sensible cooling load (W)
Ventilation					
Ventilation	38.88	0.00	0.00	-56.40	-38.01
TOTAL:				-56	-38

### Total cooling load

Total load per unit area (W/m <sup>2</sup> )	Sensible heat factor	Convective component (W)	Radiative component (W)	Latent cooling load (W)	Sensible cooling load (W)	TOTAL COOLING LOAD (W)
17.6	1.20	19.4	37.7	-51.4	305.5	254.1 W

## Loads summary

Peak cooling load	
Room: Bedroom3	Zone:
Net floor area: 22.30 m <sup>2</sup> Net volume: 57.91 m <sup>3</sup>	
Design conditions	
Indoor:	Outdoor:
Room air temperature = 24.00 °C	Dry-bulb temperature = 26.7 °C
Relative humidity = 50.00%	Wet-bulb temperature = 17.3 °C
Time of peak cooling load: 21 of July at 19h (18 apparent solar time)	

### Conduction heat gains (opaque surfaces)

	T <sub>sa</sub> (°C)	Ori. (°)	A (m <sup>2</sup> )	U (W/(m <sup>2</sup> K))	a	Tilt (°)	Convective component (W)	Radiative component (W)	Sensible cooling load (W)
Exterior surface									
Azotea	28.40	N(0)	22.30	0.29	0.60	H(0)	15.31	10.35	25.66
Fachada NE	28.39	NE(39)	8.80	0.59	0.60	V(90)	14.60	9.24	23.84
Fachada SE	28.39	SE(129)	15.90	0.59	0.60	V(90)	48.96	30.92	79.88
TOTAL:									129.4

#### Abbreviations

T <sub>sa</sub>	Sol-air temperature
Ori.	Orientation
A	Area
U	Heat transmission coefficient
a	Absorptance
Tilt	Tilt angle

### Conduction heat gains (fenestration)

	Ori. (°)	A (m <sup>2</sup> )	U <sub>global</sub> (W/(m <sup>2</sup> K))	Convective component (W)	Radiative component (W)	Sensible cooling load (W)
Exterior surface						
Ventana1	NE(39)	1.80	3.66	11.98	4.35	16.33
TOTAL:						16.3

#### Abbreviations

Ori.	Orientation
A	Area
U <sub>global</sub>	Fenestration global thermic coefficient

## Loads summary

### Solar radiation heat gain

	Ori. (°)	A (m <sup>2</sup> )	A <sub>s</sub> (m <sup>2</sup> )	q (°)	SHGC	Beam solar heat gain (W)	Diffuse solar heat gain (W)	Sensible cooling load (W)
Exterior surface								
Ventana1	NE(39)	1.80	1.80	115.93	0.68	0.00	42.31	49.69
TOTAL:								49.7

### Abbreviations

Ori.	Orientation
A	Area
A <sub>s</sub>	Sunlit area
q	Incident angle
SHGC	Center-of-glazing solar heat gain coefficient, SHGC

### Internal heat gains

	Sensible heat gain (W)	Convective component (W)	Radiative component (W)	Latent cooling gain/load (W)	Sensible cooling load (W)
Internal gains					
Occupancy	24.53	9.81	14.11	15.61	23.92
Lighting	98.12	39.25	32.42	-	71.67
Internal equipment	98.12	49.06	27.02	0.00	76.08
TOTAL:				16	172

### Ventilation and infiltration heat gains

	Airflow rate (m <sup>3</sup> /h)	Sensible heat recovery (W)	Latent heat recovery (W)	Latent cooling load (W)	Sensible cooling load (W)
Ventilation					
Ventilation	60.21	-0.00	0.00	-37.09	53.57
TOTAL:				-37	54

### Total cooling load

Total load per unit area (W/m <sup>2</sup> )	Sensible heat factor	Convective component (W)	Radiative component (W)	Latent cooling load (W)	Sensible cooling load (W)	TOTAL COOLING LOAD (W)
17.9	1.05	189.0	128.4	-21.5	420.6	399.2 W



## Loads summary

Peak cooling load	
Room: Hall	Zone:
Net floor area: 17.70 m <sup>2</sup> Net volume: 46.00 m <sup>3</sup>	
Design conditions	
Indoor:	Outdoor:
Room air temperature = 24.00 °C	Dry-bulb temperature = 28.2 °C
Relative humidity = 50.00%	Wet-bulb temperature = 18.3 °C
Time of peak cooling load: 21 of August at 15h (14 apparent solar time)	

### Conduction heat gains (opaque surfaces)

	T <sub>sa</sub> (°C)	Ori. (°)	A (m <sup>2</sup> )	U (W/(m <sup>2</sup> K))	a	Tilt (°)	Convective component (W)	Radiative component (W)	Sensible cooling load (W)
Exterior surface									
Azotea	41.85	N(0)	17.70	0.29	0.60	H(0)	8.13	5.97	14.09
Fachada SW	48.30	SW(219)	2.30	0.59	0.60	V(90)	1.47	1.69	3.16
TOTAL:									17.3

#### Abbreviations

T <sub>sa</sub>	Sol-air temperature
Ori.	Orientation
A	Area
U	Heat transmission coefficient
a	Absorptance
Tilt	Tilt angle

### Conduction heat gains (fenestration)

	Ori. (°)	A (m <sup>2</sup> )	U <sub>global</sub> (W/(m <sup>2</sup> K))	Convective component (W)	Radiative component (W)	Sensible cooling load (W)
Exterior surface						
Puerta exterior	SW(219)	1.70	2.20	8.39	2.77	11.16
TOTAL:						11.2

#### Abbreviations

Ori.	Orientation
A	Area
U <sub>global</sub>	Fenestration global thermic coefficient

## Loads summary

### Solar radiation heat gain

	Ori. (°)	A (m <sup>2</sup> )	A <sub>s</sub> (m <sup>2</sup> )	q (°)	SHGC	Beam solar heat gain (W)	Diffuse solar heat gain (W)	Sensible cooling load (W)
Exterior surface								
Puerta exterior	SW(219)	1.70	1.70	43.85	0.05	48.68	19.75	41.14
TOTAL:								41.1

### Abbreviations

Ori.	Orientation
A	Area
A <sub>s</sub>	Sunlit area
q	Incident angle
SHGC	Center-of-glazing solar heat gain coefficient, SHGC

### Internal heat gains

	Sensible heat gain (W)	Convective component (W)	Radiative component (W)	Latent cooling gain/load (W)	Sensible cooling load (W)
Internal gains					
Occupancy	38.94	15.58	23.46	24.78	39.04
Lighting	77.88	31.15	46.93	-	78.08
Internal equipment	77.88	38.94	39.11	0.00	78.05
TOTAL:				25	195

### Ventilation and infiltration heat gains

	Airflow rate (m <sup>3</sup> /h)	Sensible heat recovery (W)	Latent heat recovery (W)	Latent cooling load (W)	Sensible cooling load (W)
Ventilation					
Ventilation	47.79	-0.00	0.00	-7.67	64.80
TOTAL:				-8	65

### Total cooling load

Total load per unit area (W/m <sup>2</sup> )	Sensible heat factor	Convective component (W)	Radiative component (W)	Latent cooling load (W)	Sensible cooling load (W)	TOTAL COOLING LOAD (W)
19.6	0.95	103.7	119.9	17.1	329.5	346.6 W

## Loads summary

Peak cooling load	
Room: Bathroom	Zone:
Net floor area: 12.26 m <sup>2</sup> Net volume: 31.93 m <sup>3</sup>	
Design conditions	
Indoor:	Outdoor:
Room air temperature = 24.00 °C	Dry-bulb temperature = 26.9 °C
Relative humidity = 50.00%	Wet-bulb temperature = 17.7 °C
Time of peak cooling load: 21 of August at 19h (18 apparent solar time)	

### Conduction heat gains (opaque surfaces)

	T <sub>sa</sub> (°C)	Ori. (°)	A (m <sup>2</sup> )	U (W/(m <sup>2</sup> K))	a	Tilt (°)	Convective component (W)	Radiative component (W)	Sensible cooling load (W)
Exterior surface									
Azotea	25.83	N(0)	12.26	0.29	0.60	H(0)	5.99	4.05	10.03
Fachada NW	35.35	NW(309)	11.40	0.59	0.60	V(90)	13.98	6.27	20.25
TOTAL:									30.3

#### Abbreviations

T <sub>sa</sub>	Sol-air temperature
Ori.	Orientation
A	Area
U	Heat transmission coefficient
a	Absorptance
Tilt	Tilt angle

### Internal heat gains

	Sensible heat gain (W)	Convective component (W)	Radiative component (W)	Latent cooling gain/load (W)	Sensible cooling load (W)
Internal gains					
Occupancy	26.97	10.79	15.00	8.58	25.79
Lighting	53.94	21.58	14.04	-	35.62
Internal equipment	53.94	26.97	11.70	0.00	38.67
TOTAL:				9	100

### Ventilation and infiltration heat gains

## Loads summary

	Airflow rate (m <sup>3</sup> /h)	Sensible heat recovery (W)	Latent heat recovery (W)	Latent cooling load (W)	Sensible cooling load (W)
<b>Ventilation</b>					
Ventilation	33.10	-0.00	0.00	-12.40	31.79
TOTAL:				-12	32

<b>Total cooling load</b>						
Total load per unit area (W/m <sup>2</sup> )	Sensible heat factor	Convective component (W)	Radiative component (W)	Latent cooling load (W)	Sensible cooling load (W)	TOTAL COOLING LOAD (W)
12.9	1.02	79.3	51.1	-3.8	162.2	158.3 W

## Loads summary

### 3.2.- Heating

Peak heating load	
Room: Lounge	Zone:
Net floor area: 38.00 m <sup>2</sup> Net volume: 96.83 m <sup>3</sup>	
Design conditions	
Indoor:	Outdoor:
Room air temperature = 21.00 °C	Dry-bulb temperature = 0.40 °C
Relative humidity = 30.00%	Relative humidity = 80.00%
	Terrain temperature = 7.34 °C

### Conduction heat losses (opaque surfaces)

Produced by a version for internal use of CYPE

	Ori. (°)	A (m <sup>2</sup> )	U (W/(m <sup>2</sup> K))	Tilt (°)	Sensible heating load (W)
Exterior surface					
Roof	N(0)	38.00	0.29	H(0)	226.94
NW Façade	NW(309)	15.70	0.59	V(90)	191.75
SW Façade	SW(219)	13.80	0.59	V(90)	168.55
SE Façade	SE(129)	10.80	0.59	V(90)	131.91
TOTAL:					719.2
	A (m <sup>2</sup> )	U (W/(m <sup>2</sup> K))	Tilt (°)	Sensible heating load (W)	
Below-grade surface					
Floor	38.00	0.34	H(180)	176.51	
TOTAL:					176.5

### Abbreviations

Ori.	Orientation
A	Area
U	Heat transmission coefficient
Tilt	Tilt angle

### Conduction heat losses (fenestration)

	Ori. (°)	A (m <sup>2</sup> )	U <sub>global</sub> (W/(m <sup>2</sup> K))	Sensible heating load (W)
Exterior surface				
Window1	SW(219)	1.80	3.66	135.71
Window2	SW(219)	1.80	3.66	135.71
TOTAL:				271.4

## Loads summary

### Abbreviations

Ori.	Orientation
A	Area
$U_{\text{global}}$	Fenestration global thermic coefficient

### Ventilation and infiltration heat losses

	Airflow rate (m <sup>3</sup> /h)	Sensible heat recovery (W)	Latent heat recovery (W)	Latent heating load (W)	Sensible heating load (W)
Ventilation	102.60	-0.00	-0.00	138.87	759.74
TOTAL:				138.9	759.7

Total heating load				
Total load per unit area (W/m <sup>2</sup> )	Sensible heat factor	Latent heating load (W)	Sensible heating load (W)	TOTAL HEATING LOAD (W)
53.0	0.93	138.9	1874.1	2013.0 W

Produced by a version for internal use of CYPE

## Loads summary

Peak heating load	
Room: Kitchen	Zone:
Net floor area: 11.80 m <sup>2</sup> Net volume: 30.66 m <sup>3</sup>	
Design conditions	
Indoor:	Outdoor:
Room air temperature = 21.00 °C	Dry-bulb temperature = 0.40 °C
Relative humidity = 30.00%	Relative humidity = 80.00%
	Terrain temperature = 7.34 °C

### Conduction heat losses (opaque surfaces)

Produced by a version for internal use of CYPE

	Ori. (°)	A (m <sup>2</sup> )	U (W/(m <sup>2</sup> K))	Tilt (°)	Sensible heating load (W)
Exterior surface					
Azotea	N(0)	11.80	0.29	H(0)	70.47
Fachada SW	SW(219)	6.10	0.59	V(90)	74.50
Fachada SE	SE(129)	11.30	0.59	V(90)	138.01
TOTAL:					283.0
	A (m <sup>2</sup> )	U (W/(m <sup>2</sup> K))	Tilt (°)	Sensible heating load (W)	
Below-grade surface					
Suelo	11.80	0.34	H(180)	54.81	
TOTAL:					54.8

#### Abbreviations

Ori.	Orientation
A	Area
U	Heat transmission coefficient
Tilt	Tilt angle

### Conduction heat losses (fenestration)

	Ori. (°)	A (m <sup>2</sup> )	U <sub>global</sub> (W/(m <sup>2</sup> K))	Sensible heating load (W)
Exterior surface				
Ventana1	SW(219)	1.80	3.66	135.71
TOTAL:				135.7

#### Abbreviations

Ori.	Orientation
A	Area

## Loads summary

$U_{global}$  Fenestration global thermic coefficient

### Ventilation and infiltration heat losses

	Airflow rate (m <sup>3</sup> /h)	Sensible heat recovery (W)	Latent heat recovery (W)	Latent heating load (W)	Sensible heating load (W)
Ventilation					
Ventilation	31.86	-0.00	-0.00	43.12	235.92
	TOTAL:			43.1	235.9

Total heating load				
Total load per unit area (W/m <sup>2</sup> )	Sensible heat factor	Latent heating load (W)	Sensible heating load (W)	TOTAL HEATING LOAD (W)
59.3	0.94	43.1	656.7	699.8 W

Produced by a version for internal use of CYPE



## Loads summary

Peak heating load	
Room: Bedroom1	Zone:
Net floor area: 17.00 m <sup>2</sup> Net volume: 44.06 m <sup>3</sup>	
Design conditions	
Indoor:	Outdoor:
Room air temperature = 21.00 °C	Dry-bulb temperature = 0.40 °C
Relative humidity = 30.00%	Relative humidity = 80.00%
	Terrain temperature = 7.34 °C

### Conduction heat losses (opaque surfaces)

Produced by a version for internal use of CYPE

	Ori. (°)	A (m <sup>2</sup> )	U (W/(m <sup>2</sup> K))	Tilt (°)	Sensible heating load (W)
Exterior surface					
Azotea	N(0)	17.00	0.29	H(0)	101.53
Fachada NW	NW(309)	10.60	0.59	V(90)	129.46
Fachada NE	NE(39)	9.40	0.59	V(90)	114.81
TOTAL:					345.8
		A (m <sup>2</sup> )	U (W/(m <sup>2</sup> K))	Tilt (°)	Sensible heating load (W)
Below-grade surface					
Entarimado sobre rastreles		17.00	0.34	H(180)	78.96
TOTAL:					79.0
Abbreviations					
Ori.	Orientation				
A	Area				
U	Heat transmission coefficient				
Tilt	Tilt angle				

### Conduction heat losses (fenestration)

	Ori. (°)	A (m <sup>2</sup> )	U <sub>global</sub> (W/(m <sup>2</sup> K))	Sensible heating load (W)	
Exterior surface					
Ventana1	NE(39)	1.80	3.66	135.71	
TOTAL:				135.7	
		A (m <sup>2</sup> )	U <sub>global</sub> (W/(m <sup>2</sup> K))	Adjacent room temperature (°C)	Sensible heating load (W)
Interior partition					
Puerta al baño		1.70	2.20	24.00	-11.22

## Loads summary

TOTAL: -11.2

### Abbreviations

Ori.	Orientation
A	Area
$U_{global}$	Fenestration global thermic coefficient
$T_{ad}$	Adjacent room temperature

### Ventilation and infiltration heat losses

	Airflow rate (m <sup>3</sup> /h)	Sensible heat recovery (W)	Latent heat recovery (W)	Latent heating load (W)	Sensible heating load (W)
<b>Ventilation</b>					
Ventilation	45.90	-0.00	-0.00	62.12	339.88
TOTAL:				62.1	339.9

### Total heating load

Total load per unit area (W/m <sup>2</sup> )	Sensible heat factor	Latent heating load (W)	Sensible heating load (W)	TOTAL HEATING LOAD (W)
52.4	0.93	62.1	828.2	890.3 W

Produced by a version for internal use of CYPE

## Loads summary

Peak heating load	
Room: Bedroom2	Zone:
Net floor area: 14.40 m <sup>2</sup> Net volume: 37.40 m <sup>3</sup>	
Design conditions	
Indoor:	Outdoor:
Room air temperature = 21.00 °C	Dry-bulb temperature = 0.40 °C
Relative humidity = 30.00%	Relative humidity = 80.00%
	Terrain temperature = 7.34 °C

### Conduction heat losses (opaque surfaces)

Produced by a version for internal use of CYPE

	Ori. (°)	A (m <sup>2</sup> )	U (W/(m <sup>2</sup> K))	Tilt (°)	Sensible heating load (W)
Exterior surface					
Azotea	N(0)	14.40	0.29	H(0)	86.00
Fachada NE	NE(39)	6.30	0.59	V(90)	76.95
TOTAL:					162.9
		A (m <sup>2</sup> )	U (W/(m <sup>2</sup> K))	Tilt (°)	Sensible heating load (W)
Below-grade surface					
Entarimado sobre rastreles		14.40	0.34	H(180)	66.89
TOTAL:					66.9
Abbreviations					
Ori.	Orientation				
A	Area				
U	Heat transmission coefficient				
Tilt	Tilt angle				

### Conduction heat losses (fenestration)

	Ori. (°)	A (m <sup>2</sup> )	U <sub>global</sub> (W/(m <sup>2</sup> K))	Sensible heating load (W)
Exterior surface				
Ventana1	NE(39)	1.80	3.66	135.71
TOTAL:				135.7
Abbreviations				
Ori.	Orientation			
A	Area			
U <sub>global</sub>	Fenestration global thermic coefficient			

## Loads summary

### Ventilation and infiltration heat losses

	Airflow rate (m <sup>3</sup> /h)	Sensible heat recovery (W)	Latent heat recovery (W)	Latent heating load (W)	Sensible heating load (W)
Ventilation					
Ventilation	38.88	-0.00	-0.00	52.62	287.90
TOTAL:				52.6	287.9

### Total heating load

Total load per unit area (W/m <sup>2</sup> )	Sensible heat factor	Latent heating load (W)	Sensible heating load (W)	TOTAL HEATING LOAD (W)
49.0	0.93	52.6	653.4	706.1 W

## Loads summary

Peak heating load	
Room: Bedroom3	Zone:
Net floor area: 22.30 m <sup>2</sup> Net volume: 57.91 m <sup>3</sup>	
Design conditions	
Indoor:	Outdoor:
Room air temperature = 21.00 °C	Dry-bulb temperature = 0.40 °C
Relative humidity = 30.00%	Relative humidity = 80.00%
	Terrain temperature = 7.34 °C

### Conduction heat losses (opaque surfaces)

Produced by a version for internal use of CYPE

	Ori. (°)	A (m <sup>2</sup> )	U (W/(m <sup>2</sup> K))	Tilt (°)	Sensible heating load (W)
Exterior surface					
Azotea	N(0)	22.30	0.29	H(0)	133.18
Fachada NE	NE(39)	8.80	0.59	V(90)	107.48
Fachada SE	SE(129)	15.90	0.59	V(90)	194.20
TOTAL:					434.9
		A (m <sup>2</sup> )	U (W/(m <sup>2</sup> K))	Tilt (°)	Sensible heating load (W)
Below-grade surface					
Entarimado sobre rastreles		22.30	0.34	H(180)	103.58
TOTAL:					103.6

#### Abbreviations

Ori.	Orientation
A	Area
U	Heat transmission coefficient
Tilt	Tilt angle

### Conduction heat losses (fenestration)

	Ori. (°)	A (m <sup>2</sup> )	U <sub>global</sub> (W/(m <sup>2</sup> K))	Sensible heating load (W)
Exterior surface				
Ventana1	NE(39)	1.80	3.66	135.71
TOTAL:				135.7

#### Abbreviations

Ori.	Orientation
A	Area

## Loads summary

$U_{\text{global}}$  Fenestration global thermic coefficient

### Ventilation and infiltration heat losses

	Airflow rate (m <sup>3</sup> /h)	Sensible heat recovery (W)	Latent heat recovery (W)	Latent heating load (W)	Sensible heating load (W)
Ventilation					
Ventilation	60.21	-0.00	-0.00	81.49	445.85
			TOTAL:	81.5	445.8

Total heating load				
Total load per unit area (W/m <sup>2</sup> )	Sensible heat factor	Latent heating load (W)	Sensible heating load (W)	TOTAL HEATING LOAD (W)
53.9	0.93	81.5	1120.0	1201.5 W

Produced by a version for internal use of CYPE

## Loads summary

Peak heating load	
Room: Hall	Zone:
Net floor area: 17.70 m <sup>2</sup> Net volume: 46.00 m <sup>3</sup>	
Design conditions	
Indoor:	Outdoor:
Room air temperature = 21.00 °C	Dry-bulb temperature = 0.40 °C
Relative humidity = 30.00%	Relative humidity = 80.00%
	Terrain temperature = 7.34 °C

### Conduction heat losses (opaque surfaces)

Produced by a version for internal use of CYPE

	Ori. (°)	A (m <sup>2</sup> )	U (W/(m <sup>2</sup> K))	Tilt (°)	Sensible heating load (W)
Exterior surface					
Azotea	N(0)	17.70	0.29	H(0)	105.71
Fachada SW	SW(219)	2.30	0.59	V(90)	28.09
				TOTAL:	133.8
		A (m <sup>2</sup> )	U (W/(m <sup>2</sup> K))	Tilt (°)	Sensible heating load (W)
Below-grade surface					
Entarimado sobre rastreles		17.70	0.34	H(180)	82.21
				TOTAL:	82.2
Abbreviations					
Ori.	Orientation				
A	Area				
U	Heat transmission coefficient				
Tilt	Tilt angle				

### Conduction heat losses (fenestration)

	Ori. (°)	A (m <sup>2</sup> )	U <sub>global</sub> (W/(m <sup>2</sup> K))	Sensible heating load (W)	
Exterior surface					
Puerta exterior	SW(219)	1.70	2.20	77.04	
				TOTAL:	
		A (m <sup>2</sup> )	U <sub>global</sub> (W/(m <sup>2</sup> K))	Adjacent room temperature (°C)	Sensible heating load (W)
Interior partition					
Puerta al baño		1.70	2.20	24.00	-11.22
				TOTAL:	-11.2

## Loads summary

### Abbreviations

Ori.	Orientation
A	Area
$U_{\text{global}}$	Fenestration global thermic coefficient
$T_{\text{ad}}$	Adjacent room temperature

### Ventilation and infiltration heat losses

	Airflow rate (m <sup>3</sup> /h)	Sensible heat recovery (W)	Latent heat recovery (W)	Latent heating load (W)	Sensible heating load (W)
Ventilation	47.79	-0.00	-0.00	64.68	353.88
TOTAL:				64.7	353.9

### Total heating load

Total load per unit area (W/m <sup>2</sup> )	Sensible heat factor	Latent heating load (W)	Sensible heating load (W)	TOTAL HEATING LOAD (W)
37.1	0.90	64.7	591.9	656.6 W

Produced by a version for internal use of CYPE



## Loads summary

Peak heating load	
Room: Bathroom	Zone:
Net floor area: 12.26 m <sup>2</sup> Net volume: 31.93 m <sup>3</sup>	
Design conditions	
Indoor:	Outdoor:
Room air temperature = 24.00 °C	Dry-bulb temperature = 0.40 °C
Relative humidity = 30.00%	Relative humidity = 80.00%
	Terrain temperature = 7.34 °C

### Conduction heat losses (opaque surfaces)

Produced by a version for internal use of CYPE

	Ori. (°)	A (m <sup>2</sup> )	U (W/(m <sup>2</sup> K))	Tilt (°)	Sensible heating load (W)
Exterior surface					
Azotea	N(0)	12.26	0.29	H(0)	83.88
Fachada NW	NW(309)	11.40	0.59	V(90)	159.51
TOTAL:					243.4
	A (m <sup>2</sup> )	U (W/(m <sup>2</sup> K))	Tilt (°)	Sensible heating load (W)	
Below-grade surface					
Suelo	12.26	0.34	H(180)	69.45	
TOTAL:					69.5
Abbreviations					
Ori.	Orientation				
A	Area				
U	Heat transmission coefficient				
Tilt	Tilt angle				

### Conduction heat losses (fenestration)

	A (m <sup>2</sup> )	U <sub>global</sub> (W/(m <sup>2</sup> K))	Adjacent room temperature (°C)	Sensible heating load (W)
Interior partition				
Puerta interior1	1.70	2.20	21.00	11.22
Puerta interior2	1.70	2.20	21.00	11.22
TOTAL:				22.4
Abbreviations				
A	Area			
U <sub>global</sub>	Fenestration global thermic coefficient			

## Loads summary

$T_{ad}$  | Adjacent room temperature

### Ventilation and infiltration heat losses

	Airflow rate (m <sup>3</sup> /h)	Sensible heat recovery (W)	Latent heat recovery (W)	Latent heating load (W)	Sensible heating load (W)
Ventilation					
Ventilation	33.10	-0.00	-0.00	72.39	280.81
	TOTAL:			72.4	280.8

Total heating load				
Total load per unit area (W/m <sup>2</sup> )	Sensible heat factor	Latent heating load (W)	Sensible heating load (W)	TOTAL HEATING LOAD (W)
68.7	0.91	72.4	770.4	842.8 W


Produced by a version for internal use of CYPE

# Loads summary

## 3.3.- Graphs


Lounge

Peak cooling load (21 of August at 16h)





Produced by a version for internal use of CYPE

Peak heating load





Hourly cooling load progression (21 of August)

# Loads summary



Produced by a version for internal use of CYPE


## Annual peak cooling load progression



# Loads summary


Kitchen

Peak cooling load (21 of August at 16h)





Produced by a version for internal use of CYPE

Peak heating load





Hourly cooling load progression (21 of August)

# Loads summary



Produced by a version for internal use of CYPE


## Annual peak cooling load progression



# Loads summary


Bedroom1

Peak cooling load (21 of July at 19h)





Produced by a version for internal use of CYPE

Peak heating load





Hourly cooling load progression (21 of July)

# Loads summary



Produced by a version for internal use of CYPE

## Annual peak cooling load progression






# Loads summary


Bedroom2

Peak cooling load (21 of July at 8h)





Produced by a version for internal use of CYPE

Peak heating load





Hourly cooling load progression (21 of July)

# Loads summary



Produced by a version for internal use of CYPE


## Annual peak cooling load progression



# Loads summary


Bedroom3

Peak cooling load (21 of July at 19h)





Produced by a version for internal use of CYPE

Peak heating load





Hourly cooling load progression (21 of July)

# Loads summary



Produced by a version for internal use of CYPE


## Annual peak cooling load progression



# Loads summary


Hall

Peak cooling load (21 of August at 15h)





Produced by a version for internal use of CYPE

Peak heating load





Hourly cooling load progression (21 of August)

# Loads summary



Produced by a version for internal use of CYPE


## Annual peak cooling load progression



# Loads summary


## Bathroom

Peak cooling load (21 of August at 19h)





Produced by a version for internal use of CYPE

Peak heating load



Hourly cooling load progression (21 of August)

# Loads summary



Produced by a version for internal use of CYPE

## Annual peak cooling load progression

